

ADDENDUM NO. 1

1. GENERAL

This document includes requirements that clarify or supersede portions of the bid and/or contract requirements for the project. This Addendum is a Contract Document.

2. SUMMARY

The following changes, additions and deletions shall be made to the following document(s); all other conditions shall remain the same.

Drawings:

Sheet ME-1.2

- Add Reference Sheet Note #2: “Verify that FSD is accessible from T-bar ceiling. If it is not accessible, install 20”x30” ceiling access door in Corridor hard lid ceiling.”
- Add ceiling access door at (D.2, 3.5) and (M.4, 3.5).

Sheet ME-1.4

- Add Reference Sheet Note #2: “Verify that FSD is accessible from T-bar ceiling. If it is not accessible, install 20”x30” ceiling access door in Corridor hard lid ceiling.”
- Add ceiling access door at (D.2, 3.5) and (M.3, 3.5).

Sheet ME-1.8

- Modify Reference Sheet Note #5: “Verify FSD actuator is inside ductwork and accessible from supply opening. If it is not accessible, install 14”x24” fire-rated wall access door.”
- Modify Reference Sheet Note #6: “Verify FSD actuator is inside ductwork and accessible from supply opening. If it is not accessible, install 20”x30” ceiling access door in Vestibule.”
- Modify Reference Sheet Note #7: “Verify access to FSD from corridor ceiling access door. If FSD is not accessible, install 20”x30” ceiling access door in Band Room.”
- Add Reference Sheet Note #11: “Install fire rated access door in existing framed wall opening.” Add note at (5.2, B.7).
- Add Reference Sheet Note #12: “Install 20”x30” ceiling access door. Replace any existing soundproofing materials to match existing ceiling.”
- Change Reference Sheet Note at (5.1, B.5) from 5 to 12.
- For ceiling access doors at (3.3, C.7) and (3.3, E.5), change reference sheet note from 2 to 6.

- Add ceiling access door at (5.1, B.5).
- Remove ceiling access door at (F.4, 1.7).

Sheet ME-1.9

- Modify Reference Sheet Note #2: “Verify FSD actuator is inside ductwork and accessible from supply opening. If it is not accessible, install 20”x30” fire-rated ceiling access door in hard lid ceiling located above T-bar ceiling on first floor.”

Sheet ME-1.10

- Modify Reference Sheet Note #6: “Verify FSD is accessible from existing access door in Boys’ Toilet (G113). If it is not accessible, install 20”x30” ceiling access door in Hallway (G108).”
- Remove ceiling access doors at (U.6, 17.8), (S.4, 17.8), (H.4, 11), and (H.2, 10).
- Relocate ceiling access door at (H.4, 11.1) to (H.5, 11.1).
- For ceiling access door at (H.5, 10.1), change reference sheet note from 2 to 3.

Sheet ME-1.12

- Add Reference Sheet Note #6: “Verify FSD actuator is not inside ductwork and accessible from supply opening. If it is not accessible, replace existing ceiling access door outside Elevator Machine Room with 20”x30” ceiling access door.”
- Remove ceiling access door at (B.8, 2.3).
- For ceiling access door at (B.7, 2.2), change reference sheet note from 3 to 6.

Sheet ME-1.13

- Add Reference Sheet Note #5: “Verify FSD is not accessible from T-bar ceiling. If it is not accessible, install 20”x30” fire-rated access door in shaft wall.”
- Add Reference Sheet Note #5 to FSD-P2-1, FSD-P2-2, FSD-P2-3, FSD-P2-4, FSD-P2-5, FSD-P2-6, FSD-P2-7, FSD-P2-8, FSD-P2-9, and FSD-P2-10.

END OF DOCUMENT