

DOCUMENT 00 91 01 –

ADDENDUM NO. 1

1. GENERAL

This document includes requirements that clarify or supersede portions of the bid and/or contract requirements for the project. This Addendum is a Contract Document.

2. SUMMARY

The following changes, additions and deletions shall be made to the following document(s); all other conditions shall remain the same.

Bid Questions & Responses

1. Question: Project sketches indicate “verify color with district prior to manufacturing” Please provide a specification for the finish, i.e. powder coat, painting spec?

Response: Fence material is to be powder coated, manufacturer’s black.

2. Question: Is hand digging required at all fence posts?

Response: Hand digging is required at each fence post within the drip line of an (E) tree or near an underground utility (see section 00 11 16.1). Drilling is at the discretion of the contractor, once underground utilities are identified.

3. Question: Drawing doesn’t list a manufacture and/or reference

Response: No particular manufacture is required. Per documents, provide fence to match (E) and meet project document requirements.

4. Question: Is it acceptable to attach the fence panels to the posts with panel attachment brackets or are the panels required to be welded to the posts?

Response: Mechanical attachment with brackets is acceptable.

END OF DOCUMENT