



Preparing every student to thrive in a global society.

Request for Proposals – RFP-33-16-17

PH New CR Buildings D1&D2, IOR Services

### ADDENDUM NO. 01

The following questions have been asked by potential proposers. In order to be fair, all questions that have been received in writing are listed below and the District has provided responses. Also included in this addendum any changes, additions, deletions or corrections shall become a part of this RFP documents, for the RFP named above and all other conditions shall remain the same.

**Question:**

In reviewing the RFP, I noticed a difference in the DSA tracker classification for the IOR and the request in the RFP. The RFP calls for a Class 2 inspector, however the DSA Tracker requires the IOR to be a Class 1. Can you please verify that the project requires a Class 1 not 2?

**Response:**

This is an error in the RFP. Class 1 inspection is required.

END OF ADDENDUM NO. 01